

Executive summary

Energy scenarios developed by the International Energy Agency (IEA) suggest that carbon capture and storage (CCS) from power plants might contribute by 2050 to around 10% of the energy-related carbon dioxide (CO₂) emission reduction required to stabilise global warming (IEA, 2010). Since CO₂ capture from power generation is an emerging technology that has not been demonstrated on a commercial scale, related cost and performance information is based on feasibility studies and pilot projects and is still uncertain.

This paper analyses techno-economic data for CO₂ capture from power generation, including CO₂ conditioning and compression, in order to support energy scenario modelling and policy making. Cost and performance trends are shown based on estimates published over the last five years in major engineering studies for about 50 CO₂ capture installations at power plants. Capital cost and levelised cost of electricity (LCOE) are re-evaluated and updated to 2010 cost levels to allow for a consistent comparison. Presented data account for CO₂ capture but not transportation and storage of CO₂. They are estimates for generic, early commercial plants based on feasibility studies, which have an accuracy of on average $\pm 30\%$. The data do not reflect project-specific cost or cost for first large-scale demonstration plants, which are likely higher.

For coal-fired power generation, no single CO₂ capture technology outperforms available alternative capture processes in terms of cost and performance. Average net efficiency penalties for post- and oxy-combustion capture are 10 percentage points relative to a pulverised coal plant without capture, and eight percentage points for pre-combustion capture compared to an integrated gasification combined cycle. Overnight costs of power plants with CO₂ capture in regions of the Organisation for Economic Co-operation and Development (OECD) are about USD 3 800 per kW (/kW) across capture routes, which is 74% higher than the reference costs without capture. Cost figures vary substantially depending on the type of power plant type and fuel used. The relative increase in overnight costs compared to a reference plant without CO₂ capture is a comparably stable metric across studies. It is thus recommended for estimating cost if limited data are available. Projected LCOE is on average USD 105 per megawatt hour (/MWh). Average costs of CO₂ avoided are USD 55 per tonne of CO₂ (/tCO₂) if a pulverised coal power plant without CO₂ capture is used as a reference.

For natural gas-fired power generation, post-combustion CO₂ capture is most often analysed and appears the most attractive near-term option. Average cost and performance projections include net efficiency penalties of eight percentage points for post-combustion CO₂ capture from natural gas combined cycles. Overnight costs are USD 1 700/kW including CO₂ capture, or 82% higher than the reference plant without capture. LCOE is USD 102/MWh and costs of CO₂ avoided are USD 80/tCO₂ if a natural gas combined cycle is used as a reference.

Cost estimates stated above are average figures for OECD regions. Cost data for installations in China indicate significantly lower costs compared to the above-mentioned figures. All overnight costs include a contingency for CCS plants to account for unforeseen technical or regulatory difficulties. LCOE and costs of CO₂ avoided do not include a CO₂ emission price.

Harmonisation of costing methodologies is needed in order to simplify technology comparisons. Though a similar approach is used for estimating cost and performance across studies, specific methodologies, terminologies and underlying assumptions are inconsistent.

Broader assessments of CO₂ capture from power generation in non-OECD countries are still underrepresented, though according to global energy scenarios deployment of CCS in these regions might have to exceed expected levels in OECD countries.